

GOVERNMENT OF BIHAR
P. H. Division, Begusarai
DISTRICT LEVEL DRINKING WATER TESTING LABORATORY

Report No. :- WQ/T/01/2007 - 3203. Dt. 20.06.2023
 Ref No. :- UIS/35/23-24 Dt-17.06.2023
 Source of Sample- Boring (Treated Water).

Date of Sampling - 17.06.2023
 Sampal recieved on -17.06.2023
 Sample Collected By : School Staff.

PHYSICO-CHEMICAL TEST REPORT

Sl. No	SITE NAME	Physico - Chemical Parameters												
		pH	Turbidity	Conductivity	TDS	Total Hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Bactrological Test H2S Vails	Arsenic	Fluoride
1	Udaan International School Affiliation No-330675 School No-65673 Near-Angreji Dhala,Keshaway ,Begusarai.	7.6	BDL	338	220	262	63	17	69	252	0.14	(-)ve	BDL	0.65
	Desirable Limit*	6.5-8.5	5 NTU	-	500mg/l	300mg/l	75mg/l	30mg/l	250mg/l	200mg/l	1.0 mg/l	(+ , -)	0.01mg/l	1.0mg/l
	Permissible Limit* in absence of alternate source	NR	NR	-	2000mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	600mg/l	NR		NR	1.5mg/l
	Method of testing Parameters	pH metric	Nephelometric	Conductivity Meter	Conductivity Meter	EDTA Titration	EDTA Titration	EDTA Titration	Silver Nitrate Titration	Acid Titration	Phenonthroline Spectrophotomatic	H2S Vails	UV Spectrophotomatic	UV Spectrophotomatic

Note:-

- * (1) Drinking Water Specification Second Revision -IS:10500:2012,
- * (2) BDL = Below Detection Limit,
- * (3) Testing Methods are taken by APHA 23rd Edition 2017.
- * (4) NR = No Relaxation
- * (5) The result are reported based on materials received. Sample will be destroyed after 10 days from the date of issue of the certificate unless otherwise specified."



APPENDIX - VIII


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 2004-3203

Date : 20.06.2023

It is certified that an inspection team headed by Anil Kumar
Sinha C.E., PHED, Begusarai (Name of Officers
with designation) from PHED, Begusarai (Name of
Department/Office) inspected the Udaan International
School, Keshawey, Begusarai (Name & Address of
the School) on 17.06.2023 and found that the Udaan International
School, Keshawey, Begusarai (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One year.


कार्यपालक अभियन्ता
लोक स्वास्थ्य प्रमंडल
बेगूसराय

Signature with Seal :

Name

: Anil Kumar Sinha.

Designation

: Executive Engg.
PHED, Begusarai

To

Udaan International School
Keshawey, Begusarai
Bihar

(Name & Address of the Institution)